

GOVERNMENT OF ANDHRA PRADESH

ABSTRACT

B.R.R. Vamsadhara Project – Estimate for the work "installation of new kirloskar make 70 KVA Generator in the place of damaged Rustan generator at Gotta barrage site of B.R.R. Vamsadhara Project"– Administrative sanction-Accorded-Orders -Issued.

IRRIGATION & CAD (Proj.I) DEPARTMENT

G.O.RT.No. 549

Dated: 13-09-2014

Read the following:-

From the Chief Engineer, North Coast, Visakhapatnam, Lr. No.CE/NC/VSP/
DEE3/AEE3/BRR VDP StageI/Vol.17, Dt. 28.06.2014

ORDER:

In the reference read above, the Chief Engineer, North Coast, Visakhapatnam has submitted that the Superintending Engineer, B.R.R. Vamsadhara Project Circle, Srikakulam has stated that during Khariff and in flood seasons the gates are being operated effectively with the help of 20 HP 3 phase motors with 2 Nos. of 70 KVA Generator sets namely Kirloskar make and Ruston make installed on right flank of Gotta Barrage, whenever failure of power supply occurs. The Ruston Generator was damaged several times and it was brought into the working condition. In the month of October 2013 during philon cyclone the Ruston generator was severely damaged and it became interruption for the barrage gates to lift up immediately. As the barrage has only power operated gates, it is necessitated to install a new generator in the place of damaged Ruston generator to avoid unavoidable situations occurring in flood times.

2. The Chief Engineer, North Coast has, therefore, requested for according administrative approval for the "Installation of new kirloskar make 70 KAV Generator in the place of damaged Rustan Generator at Gotta Barrage site of B.R.R Vamsadhara Project" for an amount of Rs 5,46,000/.

3. Government after careful examination, hereby accord administrative approval for the "Installation of new kirloskar make 70 KAV Generator in the place of damaged Rustan Generator at Gotta Barrage site of B.R.R Vamsadhara Project" for an amount of Rs 5,46,000/- (Rupees five lakhs forty six thousand only) subject to auction the damaged Ruston generator and credit the amount into Government account as per Rules in vogue.

4. The estimate shall be chargeable to the Head of Account to 2700-01-155 – Vamsadhara Project Stage-I – GH(11) NSP - SH (27) – C&D – 270/272 – Maintenance.

5. The Chief Engineer, North Coast, Visakhapatnam shall take necessary action accordingly.

6. This order issues with the concurrence of Finance (W&P) Department vide their U.O.No.2162/40/W&P-II/2014, dated 01-09-2014.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

**ADITYA NATH DAS
PRINCIPAL SECRETARY TO GOVERNMENT**

To
The Chief Engineer, North Coast, Visakhapatnam

Copy To:

The Prl. AG, AP, Hyderabad.
SF/SC

//FORWARDED::BY ORDER//

SECTION OFFICER